

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Tuesday, July 31, 2018 5:03 PM
To: Aram Varjabedian; tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us)
Subject: Preliminary Reporting of SSO - Hull, MA - MA0101231 - 10-12 Rockaway Ave.
Attachments: IMG_9708.JPG; IMG_9730.JPG

Good afternoon:

This email is to report a sanitary system overflow [SSO] that occurred yesterday at 10-12 Rockaway Ave. The SSO was the result of a failed grinder pump that services two homes. The pump failure caused the pump chamber to fill up and spill out onto the ground. The release was estimated at less than 40 gallons.

A call came into the Hull Sewer Department office at 10:45am on Monday 7/30/18. Woodard & Curran staff were dispatched to this location and a call also made to Rosano-Davis at the same time for a septic pump truck to meet at the residence.

The pump truck arrived at 11:35am and pumped down the E-1 pump chamber as well as the small amount of sewage that reached nearby storm drain. The storm drain sump was cleaned out and no release into the drainage system

Lime was applied to the areas where sewage leaked out onto the ground. The failed pump was replaced.

A full report will follow.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS